



Calhoun: The NPS Institutional Archive
DSpace Repository

Theses and Dissertations

1. Thesis and Dissertation Collection, all items

1947

An investigation of the efficiency effects of gas turbine flexibility with bleed-off utilization

Bodnaruk, Andrew

Troy, New York; Rensselaer Polytechnic Institute

<http://hdl.handle.net/10945/6447>

Downloaded from NPS Archive: Calhoun



<http://www.nps.edu/library>

Calhoun is the Naval Postgraduate School's public access digital repository for research materials and institutional publications created by the NPS community. Calhoun is named for Professor of Mathematics Guy K. Calhoun, NPS's first appointed -- and published -- scholarly author.

Dudley Knox Library / Naval Postgraduate School
411 Dyer Road / 1 University Circle
Monterey, California USA 93943

Thesis
B6

AN INVESTIGATION OF THE EFFICIENCY EFFECTS
OF GAS TURBINE FLEXIBILITY WITH
BLEED-OFF UTILIZATION

Andrew Bodnaruk

Thesis
B6

Thesis
B6

Woot
JTB

An Investigation of the Efficiency Effects of Gas Turbine
Flexibility with Bleed-Off Utilization.

A Thesis

Lt.(jg) Andrew Bodnaruk USN

June 1947

Rensselaer Polytechnic Institute

Troy, New York

A thesis presented to the faculty of Rensselaer Poly-
technic Institute in partial fulfillment of the
requirements for the degree of Master of Science.

Acknowledgements

The writer wishes to acknowledge with deep appreciation the fact that the theme of this thesis is based upon a suggestion made by Professor Neil P. Bailey. The method for the fundamental investigation of General Compressor Stability and General Compressor-Burner Stability used is based upon a method presented by Professor Neil P. Bailey and is presented with his permission. He also wishes to acknowledge with gratitude the understanding of his wife, Ann Catherine, who has had to live and share her home with so inanimate a subject as "An Investigation of the Efficiency Effects of Gas Turbine Flexibility with Bleed-Off Utilization."

Table of Contents

Article		Page
	Introduction.	1
I	General Compressor Stability Conditions with Bleed-Off Air	4
II	General Compressor-Burner Stability Conditions with Bleed-Off Air	9
III	Results of Mathematical Computations- Tables and Graphs	18
IV	Effect of Bleed-Off Air Utilization on the Various Systems	27
V	Sample Calculations	36
VI	Bibliography	47

Table of Illustrations

Figure	Page
1 Compressor Bleed-Off	4
2 General Gas Turbine Unit	36
3 Weight Flow Variation with Pressure	5
4 Compressor Weight Flow Curve	7
5 Efficiency Tabulations.	20

Curve	Page
I Efficiency vs. Pressure Ratio Simple Cycle. . .	21
II Efficiency vs. Pressure Ratio - Simple Cycle 50% Compressor Intercooling.	22
III Efficiency vs. Pressure Ratio- Simple Cycle 100% Compressor Intercooling	23
IV Efficiency vs. Pressure Ratio-Turbine Compounding.	24
V Efficiency vs. Pressure Ratio- Turbine Compounding, 50% Compressor Intercooling. . .	25
VI Efficiency vs. Pressure Ratio-Turbine Compounding, 100% Compressor Intercooling. . .	26

Symbols Used

C_v = Specific heat at constant volume, BTU/lb/deg F.

C_p = Specific heat of constant pressure, BTU/lb./deg F.

g = 32.2 ft. per sec. per sec.

J = 778.26 ft. lb per Btu

L = Mechanical work

P = Absolute pressure, lb. per sq. ft.

Q = Heat added or removed, Btu

R = Gas Constant, 53.3 for air

T = Static Temperature, deg. Rankine

T_o = Total temperature, deg. Rankine

v = velocity, ft. per sec.

V = Specific volume, cu.ft. per lb.

W = Flow, lb. per sec.

w = Fuel, lbs per lb. air

INTRODUCTION

Engineering study of the possibilities of the gas turbines as a drive for ship propulsion has been conducted in this country by various large industrial firms. Various arrangements have been considered including the electrical and hydro-mechanical transmissions. The principle difficulty in the development of an efficient gas turbine has been the need for high temperature alloys. This difficulty has been overcome with the introduction of various steel alloys such as 16-256-6 and the Cobalt-Chromium-Columbium alloys. The introduction of these metals has now put gas turbine development on a par with the larger steam plant developments. For ship drives the combustion gas turbine cycle offers efficiency equal to the best maritime steam power plants, which have a maximum over-all efficiencies of about 25%. Weight and space requirements of equipments are a serious factor in this application. The gas cycle eliminates the steam generator, the steam condenser. Without doubt the gas cycle plant will offer a decided decrease in weight and space requirements, despite the air compressor, the regenerator, and the gas turbine.

Although gas turbine cycle efficiency is comparable with steam plant efficiency the gas turbine is essentially a point design. Great savings in weight and space requirements are effected by gas turbine installation. The point design of a gas turbine is that point at which maximum efficiency is obtained. Any excessive variance from this designed point

(i.e., partial load) brings a corresponding decrease in the system efficiency. This factor is readily understood when we come to consider that compressor design in its present stage of development can vary little from its designed load without seriously decreasing the compressor efficiency. This also applies to some extent to the turbine efficiency. Various methods have been proposed to increase the efficiency of the gas turbine cycle at partial load. The use of separate turbines improves the partial load performance since the compressor and its drive turbine can operate independently at their optimum designed speed regardless of the speed or load requirements of the major power turbine.

*

It has been proposed that for ship manoeuvring conditions that rapid acceleration may be obtained by employing a by-pass valve ahead of the power turbine in operating the compressor at full load. Any excess gas not required by the power turbine for any given load under which it may be operated can be discharged to the atmosphere through the by-pass valve. The closing of this by-pass valve and thus sending this bleed-off air again to the power turbine will produce maximum torque characteristics. It has been noted that marine propeller torque speed characteristics are such that during reversing operations while the propeller is


*Dr. J.T. Rettaliata "Gas Turbine" Power January 1944

still rotating ahead the maximum torque requirements for reversing occur at approximately 40% of the normal shaft speed. The torque speed characteristics of the gas turbine can fulfill this condition; the gas turbine will thus have approximately the same acceleration and power characteristics as the present day marine steam turbine.

Present day gas turbine plants yield good efficiency and flexibility from 75% full load to full load. It is the purpose of this paper to investigate the possibilities of taking this bleed-off air as proposed and passing it through a separate turbine wheel. This turbine wheel will of necessity be isolated from the high temperature wheels due to the high temperature differential. Since compressor stability and compressor-burner stability are important factors in flexibility control the interpretation of this analysis will yield the important information which will make bleed-off analysis feasible; this will be undertaken and presented. The added increase in efficiency in the vicinity of $\frac{1}{2}$ load will be investigated with various types of gas turbines as exist in present day development. The author will endeavor to find the most appropriate gas turbine unit which will yield the optimum conditions for flexibility and efficiency for good partial load characteristics.

I. GENERAL COMPRESSOR STABILITY CONDITIONS WITH BLEED-OFF AIR

A. In the analysis of the gas turbine flexibility as proposed we must of necessity reflect and develop the effects upon the system as a whole, and in measure upon the individual parts of this system. Under given conditions encountered in actual practise it is known that a continuous flow compressor coupled with a burner and fuel system may become unstable. It is of utmost importance that such conditions be understood, for often it becomes a major limitation in gas turbine design. The author wishes to present the development of compressor stability with consideration of bleed-off air as proposed.



B. During a transient disturbance we know that the rate of flow entering equals the rate of flow leaving plus the rate of storage. The instantaneous conditions during the disturbance are W_1, W_2, W_x and P , where:

- (1) $W_1 - W_x$ = rate of flow entering
- (2) W_2 = rate of flow leaving
- (3) $\frac{dW}{dt}$ = rate of storage


Since $W = \frac{PV}{nRT}$ equation (3) becomes

$$(3a) \quad \frac{d\left(\frac{PV}{nRT}\right)}{dt} = \text{rate of storage}$$

Thus we can state B in the following manner:

$$(4) \quad W_1 - W_x = W_2 \div \frac{d\left(\frac{PV}{nRT}\right)}{dt}$$

C. The variation of weight flow thru the system with pressure can be expressed by the general curve as shown below.



Now letting W_0, P_0 represent any initial steady state conditions, we can express any change in W_1 , $W_1 - W_x$ and W_2 with pressure as $\frac{dW}{dP}$ where

$$(1) \quad \frac{dW}{dP} = \frac{W_1 - W_0}{P - P_0}$$

and,

$$(2) \quad (W_1 - W_0) = \frac{dW_1}{dP} (P - P_0)$$

$$(3) \quad (W_1 - W_x - W_0) = \frac{d(W_1 - W_x)}{dP} (P - P_0)$$

$$(4) \quad (W_2 - W_0) = \frac{d(W_2)}{dP} (P - P_0)$$

We can now state equation B(4) in terms of variations in flow from the original steady state conditions:

$$(5) \quad (W_1 - W_x - W_0) = (W_2 - W_0) \div \frac{d\left(\frac{PV}{nRT}\right)}{dt}$$

or,

$$(6) \quad \frac{d(W_1 - W_x)}{dP} (P - P_0) = \frac{dW_2}{dP} (P - P_0) \div \frac{d\left(\frac{PV}{nRT}\right)}{dt}$$

simplifying,

$$(7) \quad \frac{dW_1}{dP} (P - P_0) = \frac{dW_2}{dP} (P - P_0) \div \frac{dW_x}{dP} (P - P_0) \div \frac{d\left(\frac{PV}{nRT}\right)}{dt}$$

At this point let us assume that there is no variation in temperature with pressure. We know this to be untrue, but make the assumption for the sake of simplicity in the analysis. With this assumption, equation C (7) may be simplified to:

$$(8) \quad \frac{dp}{dt} - \frac{nRT}{V} \left(\frac{dw_1}{dp} - \frac{dw_2}{dp} - \frac{dw_x}{dp} \right) P = P_0 \left(\frac{dw_1}{dp} - \frac{dw_2}{dp} - \frac{dw_x}{dp} \right)$$

Upon examination we see that equation C(8) is in the form of a linear differential equation:

$$(9) \quad \frac{dp}{dt} + AP = B$$

The solution of this type equation can be accomplished by multiplying equation C(9) by E^{AT} to obtain:

$$(10) \quad E^{AT} \frac{dp}{dt} + APE^{AT} = BE^{AT} \quad \text{WHERE}$$

$$(11) \quad \frac{d(PE^{AT})}{dt} = BE^{AT}$$

$$(12) \quad PE^{AT} = BE^{AT}t + C_1$$

$$(13) \quad PE^{AT} = \frac{B}{A} E^{AT} + C$$

$$(14) \quad P = \frac{B}{A} + C_1 E^{-AT}$$

Now applying this integrating procedure to equation B(8) we obtain:

$$(15) \quad P = P_0 + C_1 E^{-\frac{nRT}{V} \left(\frac{dw_1}{dp} - \frac{dw_x}{dp} - \frac{dw_2}{dp} \right) t}$$

or,

$$(16) \quad P = P_0 + C_1 E^{-\frac{W_0 RT}{P_0} \left(\frac{1}{\frac{W_0}{P_0} \frac{dp}{dw_1}} - \frac{1}{\frac{W_0}{P_0} \frac{dp}{dw_x}} - \frac{1}{\frac{W_0}{P_0} \frac{dp}{dw_2}} \right) t}$$


or,

$$(17) \quad P = P_0 C_1 E^{-\frac{nRT}{V} \frac{dw_2}{dp} t} E^{-\frac{nRT}{V} \frac{dw_x}{dp} t} E^{-\frac{nRT}{V} \frac{1}{\frac{dp}{dw_1}} t}$$

Where: $E^{-\frac{nRT}{V} \frac{dw_2}{dp}}$ and $E^{-\frac{nRT}{V} \frac{dw_x}{dp}}$ define the characteristics of the load and $E^{-\frac{nRT}{V} \frac{1}{\frac{dp}{dw_1}} t}$ defines the characteristics of the compressor.

D. Significance of Mathematical Results.

Let us examine a typical Pressure versus Weight of Air Delivered Curve.



The $\frac{nRT}{v} \frac{dW_2}{dP}$ and $\frac{nRT}{v} \frac{dW_x}{dP}$ define the characteristics of the load as stated above, and we know that $\frac{nRT}{v} \frac{dW_2}{dP}$ is always positive irrespective of the load. Therefore in analysis we notice that the $\frac{nRT}{v} \frac{dW_x}{dP}$ will yield to the system the same effect as that yielded to the system by $\frac{nRT}{v} \frac{dW_2}{dP}$ having negative slope stability for the compressor will result for the exponent of (E) in our equation (17) will be negative and any disturbance to the system will be damped out. Now noting that $\frac{nRT}{v} \frac{dW_x}{dP}$ carries the same sign as $\frac{nRT}{v} \frac{dW_2}{dP}$ it always will tend to stabilize the system, and any disturbance to the system will also tend to damp out. Thus upon the basis of this analysis we are encouraged to investigate further this proposal of bleed-off air for flexibility, for it shows decided possibilities.

Let us then, determine the significance of the term which defines the characteristics of the compressor,

$\frac{nRT}{v} \frac{1}{\frac{dP}{dW_1}}$. For good stability characteristics this term

must remain negative, for if the term goes thru zero and δ the slope becomes slightly positive, the exponent (E) of equation (17) will become plus and any disturbance will be amplified.

With the promising results of the stability effects of the proposed bleed-off; it is the purpose of the author to present in this and the following sections the effects of this bleed-off on the efficiencies and outputs of various gas turbine installations as proposed for present day power installations. It is to be remembered that the proposal of bleed-off is one which will be undertaken at loads below full load with an eye to increasing the efficiency by sending this bleed-off air thru a separate turbine wheel on the power unit.

II. GENERAL COMPRESSOR-BURNER STABILITY CONDITIONS WITH BLEED-OFF AIR

A. Referring to diagram in section I; during a transient disturbance the rate of flow entering equals the rate of leaving plus the rate of storage.

Where: W_1, W_2, W_x and P are the instantaneous conditions during the disturbance and,

$$(1) W_1 - W_x = \text{rate of flow entering}$$

$$(2) W_2 = \text{rate of flow leaving}$$

$$(3) \frac{dW}{dt} = \text{rate of storage}$$

Since $W = \frac{PV}{nRT}$ equation (3) becomes
(3a) $\frac{d(\frac{PV}{nRT})}{dt} = \text{rate of storage}$

therefore, from A:

$$(4) W_1 - W_x = W_2 + \frac{d(\frac{PV}{nRT})}{dt}$$

The variation of weight flow thru the system with pressure variation can be expressed by the general curve as shown in Section I-C. Letting W_0, P_0 , represent any initial steady state conditions, the slope of the curve will be

$$\frac{W_1 - W_0}{P - P_0} = \frac{dW_1}{dP}$$

$$\text{or, } (5) W_1 = (P - P_0) \frac{dW_1}{dP} + W_0$$

$$(6) W_2 = (P - P_0) \frac{dW_2}{dP} + W_0$$

$$(7) W_x = (P - P_0) \frac{dW_x}{dP} + W_0$$

and substituting equations 5, 6, and 7 in 4:

$$(P - P_0) \frac{dW_1}{dP} + W_0 = (P - P_0) \frac{dW_2}{dP} + W_0 + (P - P_0) \frac{dW_x}{dP} + W_0 + \frac{d(\frac{PV}{nRT})}{dt}$$

Since both pressure and temperature vary with time the rate of

$$\text{storage} = \frac{d}{dt} \frac{PV}{nRT} = \frac{V}{nRT} \frac{dP}{dt} - \frac{PV}{nRT^2} \frac{dT}{dt} \text{-----}(8)$$

It is to be noted that the usual pressure-weight flow curves for a compressor are taken for steady state conditions and can not be taken directly to predict transient conditions for they do not take into consideration inertia effects. One method of including such effects is to put forth the fact that during a transient condition, a compressor will deliver air at a pressure P where

(9) $P = P_1 - I \frac{dw_1}{dt}$ and P_1 is the pressure obtained neglecting inertia effects; $I \frac{dw_1}{dt}$ is the inertia effect. Now the rate of pressure change in the system becomes:

$$(10) \frac{dP}{dt} = \frac{dP_1}{dw_1} \frac{dw_1}{dt} - I \frac{d^2w_1}{dt^2}$$

Setting up a heat balance for the system

$$(11) (w_1 - w_x) C_p (T - T_1) = wH;$$

where H is the heating value of the fuel. Differentiating equation (11) with respect to time; assuming $T_1 = \text{constant}$

$$(12) (w_1 - w_x) C_p \frac{dT}{dt} - C_p (T - T_1) \left(\frac{dw_1}{dt} - \frac{dw_x}{dt} \right) = H \frac{dw}{dt} = \frac{H}{dP} \frac{dw}{dP} \frac{dP}{dt}$$

$$(13) \frac{dT}{dt} = \frac{H}{(w_1 - w_x) C_p} \frac{dw}{dP} \frac{dP}{dt} - \frac{(T - T_1)}{(w_1 - w_x)} \frac{dw_1}{dt} - \frac{dw_x}{dt}$$

$$dT = \frac{H}{(w_1 - w_x) C_p} \frac{dw}{dP} dP - \frac{T - T_1}{(w_1 - w_x)} \frac{(dw_1 - dw_x)}{dP} dP$$

With equation (13) substituted in (8) rate of storage =

$$\frac{V}{nRT} \frac{dP}{dt} - \frac{PV}{nRT^2} \left(\frac{H}{(w_1 - w_x) C_p} \frac{dw}{dP} - \frac{T - T_1}{w_1 - w_x} \left(\frac{dw_1}{dt} - \frac{dw_x}{dt} \right) \right)$$

or rate of storage =

$$(14) \quad \frac{1}{n} \left(\frac{V}{RT} - \frac{PV_0 H}{RT^2 (W_1 - W_x) C_p} \frac{dw}{dP} \right) \left(\frac{dP_1}{dW_1} \frac{dW_1}{dt} - I \frac{d^2 W_1}{dt^2} \right) /$$

$$\frac{PV}{nRT^2} \frac{(T - T_1)}{(W_1 - W_x)} \left(\frac{dW_1}{dt} - \frac{dW_x}{dt} \right)$$

If the burner is operating at velocities high enough to be near the acoustic $\frac{W_2(T_0)^{\frac{1}{2}}}{PA} = \text{constant}$

or $W_2 = \frac{P}{K(T)^{\frac{1}{2}}}$ and taking ln we have:

$$\ln W_2 = \ln K / \ln P - \frac{1}{2} \ln T$$

taking the differential:

$$(15) \quad \frac{dW_2}{W_2} = \frac{dP}{P} - \frac{1}{2} \frac{dT}{T} \quad \text{and}$$

$$(16) \quad dW_2 = \frac{W_2 dP}{P} - \frac{W_2}{2} \frac{dT}{T}$$

In analysis: At the onset of any transient with the changes of W , T , and P from the steady state values are small; thus we can integrate equation (16b)

$$(16a) \quad dW_2 = \frac{W_2}{P} dP - \frac{W_2}{2T} \left(\frac{H}{C_p (W_1 - W_x)} \frac{dw dP}{dP} - \frac{T - T_1}{W_1 - W_x} \frac{dW_1 - dW_2}{dP} dP \right)$$

$$(16b) \quad dW_2 = \left(\frac{W_2}{P} - \frac{W_2}{2T} \frac{H}{C_p (W_1 - W_x)} \frac{dw}{dP} \right) dP / \frac{W_2 (T - T_1)}{2T (W_1 - W_x)} (dW_1 - dW_2)$$

$$(17) \quad W_2 - W_0 = \left(\frac{W_0}{P_0} - \frac{H}{2T_0 C_p} \frac{dw}{dP} \frac{1}{(W_1 - W_x)} \right) P - P_0 / \frac{(T_0 - T_1)}{2T_0} \frac{(W_1 - W_2)}{(W_1 - W_x)}$$

From equation 9

$$(18) \quad P - P_0 = (P_1 - P_0) - I \frac{dW_1}{dt} \quad \text{and for small changes}$$

$$(19) \quad P_1 - P_0 = (W_1 - W_0) \frac{dP_1}{dW_1} \quad \text{and substituting equation (19) in equation (18)}$$

$$(20) \quad P - P_0 = (W_1 - W_0) \frac{dP_1}{dW_1} - I \frac{dW_1}{dt} \quad \text{and from equation (20)}$$

and equation (17)

$$(21) \quad W_2 - W_0 = \left(\frac{W_0}{P_0} - \frac{H}{2T_0 C_p} \frac{dw}{dP} (W_1 - W_x) \right) \left((W_1 - W_0) \frac{dP_1}{dW_1} - I \frac{dW_1}{dt} \right) + \frac{(T_0 - T_1) (W_1 - W_2)}{2T_0 (W_1 - W_x)}$$

$$(21a) \quad W_2 - W_0 = \left(\frac{W_0}{P_0} - \frac{H}{2T_0 C_p} \frac{dw}{dP} (W_1 - W_x) \right) \left((P_1 - P_0) - I \frac{dW_1}{dt} \right) + \frac{(T_0 - T_1) (W_1 - W_2)}{2T_0 (W_1 - W_x)}$$

$$(22) \quad W_2 - W_0 = \frac{W_0}{P_0} - \frac{H}{2T_0 C_p} \frac{(W_1 - W_0)}{(W_1 - W_x)} \frac{dw}{dP} \frac{dP_1}{dW_1} + \frac{(T_0 - T_1) (W_1 - W_2)}{2T_0 (W_1 - W_x)} - I \left(\frac{W_0}{P_0} - \frac{H}{2T_0 C_p} \frac{dw}{dP} (W_1 - W_x) \right) \left(\frac{dW_1}{dt} \right)$$

During a transient condition equation (1) become s

$$(23) \quad (W_1 - W_0) = (W_2 - W_0) + (W_x - W_0) \quad \text{rate of storage}$$

and now substituting equations (22) and (14), we obtain the following result:

$$(24) \quad \frac{d^2(W_1 - W_0)}{dt^2} - \frac{d(W_1 - W_0)}{dt} \left(I \left(\frac{W_0}{P_0} - \frac{H}{2T_0 C_p} \frac{dw}{dP} (W_1 - W_x) \right) - \frac{P_0 V (T_0 - T_1)}{n R T_0^2 (W_1 - W_x)} - \frac{1}{n} \frac{dP_1}{dW_1} \frac{V}{RT_0} - \left(\frac{P_0 V H}{RT_0^2 (W_1 - W_x) C_p} \right) \left(\frac{dw}{dP} \right) \right) - \frac{1}{n} \left(\frac{V}{RT_0} - \frac{P_0 V H}{RT_0^2 (W_1 - W_x)} \frac{dw}{dP} \right) = 0$$

$$+ (W_1 - W_0) \left(\frac{1}{n} \left(\frac{V}{RT_0} - \frac{P_0 V H}{RT_0^2 (W_1 - W_x)} \frac{dw}{dP} \right) \frac{dP_1}{dW_1} + \frac{T_0 - T_1}{2T_0} \right) = 0$$

We shall review for a moment the solution for second order differential equations. Equation (24) may be written

$$(25) \quad \frac{d^2(W_1 - W_0)}{dt^2} + a \frac{d(W_1 - W_0)}{dt} + b(W_1 - W_0) = 0$$

and assuming $(W_1 - W_0) = x$ thus (25) becomes

$$(26) \quad \frac{d^2x}{dt^2} + a \frac{dx}{dt} + b(x) = 0$$

Let operator $D = \frac{d}{dt}$ and $D^2 = \frac{d^2}{dt^2}$ therefore:

$$(D^2 + aD + b)x = 0$$

Setting $D^2 + aD + b = 0$

$$D = \left\{ -\frac{a}{2} \pm \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\}, \quad D = \left\{ -\frac{a}{2} - \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\}$$

$$\left\{ D - \frac{a}{2} - \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} \left\{ D - \frac{a}{2} + \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} x = 0$$

$$\frac{dy}{dt} + \left\{ \frac{a}{2} - \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} y = 0$$

multiplying by E

$$E \frac{dy}{dt} + \left\{ \frac{a}{2} - \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} Ey = 0$$

$$\frac{\frac{dyE}{dt} + \left\{ \frac{a}{2} - \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} t}{dt} = 0$$

$$yE \left\{ \frac{a}{2} - \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} t = C_1$$

$$\frac{dx}{dt} + \left\{ \frac{a}{2} + \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} x = C_1 E \left\{ -\frac{a}{2} + \left\| \left(\frac{a}{2}\right)^2 - b \right\|^{\frac{1}{2}} \right\} t$$

$$x = C_1 E \left\{ -\frac{a}{2} \sqrt{\left| \frac{a}{2} \right|^2 - b} \right\}^{\frac{1}{2}} t \quad \div C_2 E \left\{ -\frac{a}{2} \sqrt{\left| \frac{a}{2} \right|^2 - b} \right\}^{\frac{1}{2}} t$$

and

$$(26) \quad W_1 - W_0 = E \frac{a}{2} t \left\{ \left| \frac{a}{2} \right|^2 - b \right\}^{\frac{1}{2}} \div C_1 E \left\{ -\left| \frac{a}{2} \right|^2 - b \right\}^{\frac{1}{2}} t$$

and with the aid of equation (12) we obtain the following result:

$$(28) \quad a = \frac{P_0 n}{W_0 I} \frac{I R T_0 W_0^2}{V P_0^2} \left\| \frac{1 - P_0}{w} \frac{dw}{dP} \frac{T_0 - T_1}{2 T_0} \right\| - \frac{T_0 - T_1}{n T_0} \left\| -\frac{W_0}{n P_0} \frac{dP_1}{d(W_1 - W_x)} \left(1 - \frac{P_0}{w} \frac{dw}{dP} \frac{(T_0 - T_1)}{T_0} \right) \right\|$$

$$\left\| \frac{1 - \frac{P_0}{w} \frac{dw}{dP} \frac{(T_0 - T_1)}{T_0}}{1 - \frac{P_0}{w} \frac{dw}{dP} \frac{(T_0 - T_1)}{T_0}} \right\|$$

$$(29) \quad b = \left\| \frac{\frac{1 - W_0}{P_0} \frac{dP_1}{d(W_1 - W_x)} \left\| 1 - \frac{P_0}{w} \frac{dw}{dP} \frac{T_0 - T_1}{2 T_0} \right\| \div \frac{T_0 - T_1}{2 T_0}}{\frac{VI}{n R T_0} \left\| 1 - \frac{P_0}{w} \frac{dw}{dP} \frac{T_0 - T_1}{T_0} \right\|} \right\|$$

B. The significance of results obtained from the mathematical development in Section II A may be stated as follows. Equation (26) is the stability equation and will apply to this system as developed if the magnitude of the disturbance is not too great. In analysis when (a) remains a plus number any disturbance to the system will be damped out; if (a) becomes a minus number any disturbance to the system will be amplified. Let us further examine our system and the effect of air inertia, for we shall later see that air inertia plays a very important part in the compressor-burner stability. In the case of no burning at the burner $T_0 = T_1$ and $n = 1$ and investigating this effect on (a) we find

$$(30) \quad a = \frac{IRT_1 W_0^2}{VP_0^2} - \frac{W_0}{P_0} \frac{dP_1}{d(W_1 - W_x)}$$

This equation indicates that the effect of air inertia and our bleed off air is to make possible stable operation without burning, even where our slope of $\frac{dP_1}{d(W_1 - W_x)}$ is slightly positive.

In stability to the system commences at the point when

$$(31) \quad \frac{dP_1}{d(W_1 - W_x)} > \frac{IRT_1 W_0}{VP_0}$$

It is to be remembered that the inertia effect is not an easy effect to calculate for it is a factor inherent to a given system. However it is important to remember that the inertia effect will be essentially the same in case of no burning as

as with burning, provided the flow and pressure are the same. The condition for pulsation for a given value of I is given by the equation, (where $\frac{dw}{dP} = 0$)

$$(32) \left(\frac{W_1 - W_x}{P} \right) \frac{dP_1}{d(W_1 - W_x)} = \frac{nT_0}{T} \left(\frac{W_1 - W_x}{P} \frac{dP}{d(W_1 - W_x)} - \left(\frac{T_0 - T_1}{T_0} \right) \right)$$

In analysis for cases of low air inertia the effect of burning is to foster pulsation (assume temperature ratio in combustion chamber equal to 5) in a system that would otherwise be stable with no burning. To further examine this effect of burner temperature on stability let us consider the limit of stability to a system with no air inertia, or

$$\left(\frac{W_1 - W_x}{P} \right) \frac{dP}{d(W_1 - W_x)} = 0$$

This yields,

$$(33) \left(\frac{W_1 - W_x}{P} \right) \frac{dP}{d(W_1 - W_x)} \frac{T_0 - T_1}{T_0} \text{ knowing gas stored in burner,}$$

$$(34) \frac{d \left(\frac{PV}{nRT} \right)}{dP} = \frac{V}{nRT} \left(1 - \frac{P}{T_0} \frac{dT_0}{d(W_1 - W_x)} \frac{d(W_1 - W_x)}{dP} \right)$$

Returning to the original heat balance equation (12) with $\frac{dw}{dP} = 0$

$$(35) \frac{dT_0}{d(W_1 - W_x)} = - \frac{T_0 - T_1}{W_1 - W_x}$$

This yields

$$(36) \frac{d \left(\frac{PV}{nRT} \right)}{dP} = \frac{V}{nRT} \left(1 - \frac{T_0 - T_1}{T_0} \frac{\frac{dP_1}{d(W_1 - W_x)}}{\frac{W_1 - W_x}{P}} \right)$$

In interpretation, when the conditions in the system are such that equation (33) is satisfied from equation (36) we observe that an increase in pressure to the system is accompanied by an increase in flow weight stored in the burner. This is the desired situation, the stable condition. We may conclude from the above analysis that our proposal of bleed-off air and its resultant effect on compressor-burner stability is one which shows promising application - for the effect is one which tends to maintain system stability.

III. RESULT OF MATHEMATICAL COMPUTATIONS

TABLES AND GRAPHS

A. The gas turbine of the constant pressure combustion type comprises three components; the compressor, the combustion chamber, and the turbine. Computations were first carried out for a simple cycle, operating at full load with half load bleed-off. Curves were plotted representing efficiency versus pressure ratios of four, eight and twelve to one respectively. -(Curve I A) A heat regenerator was added to this cycle and a curve of efficiency versus pressure ratio was also plotted for this cycle variation.- (Curve I B.) The efficiency increase over these two systems due to the utilization of bleed-off air via the additional turbine wheel was plotted and is represented by curve I C and I D respectively.

B. The simple cycle with and without regenerator was then subjected to the effects of compressor compounding of 50 and 100%. The efficiency of this variation versus pressure ratio is represented by curves II A₁, and II B₁ for 50% cooling; curve IIA₁ without generator, curve II B₁ with regenerator. The effect of the utilization of bleed-off air is represented by curve II C₁ for the system without regenerator, and curve II D₁ for system with regenerator.

C. The same procedure of labeling has been followed

in the case of compressor compounding 100% cooling. The curves are of the set III and are denoted by subscript 2.

D. We then subject the simple cycle to turbine compounding; i.e. after the first stage expansion the gas is reheated to its original temperature and then expanded in the second stage. The same system of labeling as outlined in paragraph B of this section has been followed. (Curves IV A₃, B₃, C₃, D₃)

E. Curves V A₄, B₄, C₄, D₄, represent turbine compounding combined with compressor compounding 50% cooling.


F. Curves VI A₅, B₅, C₅, D₅, represent turbine compounding combined with compressor compounding with 100% cooling.

G. It is to be noted that T, S diagrams have been drawn representing the various complex systems on the curves to simplify the understanding of the curves.


TYPE OF INSTALLATION	SIMPLE			COMPRESSOR COMPOUNDING						TURBINE				COMBINED COMPOUNDING					
PRESSURE RATIO	4	8	12	50% cooling		100% cooling		100% cooling		Compounding			50% cooling		100% cooling				
	4	8	12	4	8	12	4	8	12	4	8	12	4	8	12	4	8	12	
$T_{02} = 1500^{\circ}\text{R}$, $n_t = n_c = .85$ $n_w = .60$																			
Eff. without regenerator (a)	.088	.078	.060	.087	.086	.060	.038	.097	.090	.089	.106	.095	.087	.108	.104	.088	.114	.118	
Eff. with regenerator (b)	.091	.078	.060	.106	.097	.066	.106	.107	.094	.111	.127	.118	.112	.126	.118	.111	.129	.129	
% increase efficiency	3.40	.000	.000	22.9	13.3	9.40	20.3	9.40	4.60	30.7	20.4	19.0	28.5	16.7	13.2	25.9	13.4	2.20	
Eff. with bleed-off use (a)	.117	.097	.067	.101	.116	.068	.102	.133	.094	.120	.155	.125	.109	.156	.130	.110	.157	.160	
% increase over (a)	27.7	19.6	11.7	16.1	34.8	13.3	15.9	37.0	3.90	33.0	46.1	31.6	24.0	45.4	24.0	24.8	37.8	38.5	
Eff. with bleed-off use (b)	.125	.097	.067	.142	.123	.069	.134	.142	.098	.147	.180	.150	.134	.178	.163	.134	.182	.184	
% increase over (a)	42.0	19.6	11.7	62.0	43.0	15.0	52.4	46.5	9.70	65.0	69.9	58.0	54.0	65.0	56.5	52.2	59.6	60.3	

NEUFEL & BATES CO., N. Y. NO. 38-11
 10 x 10 to the 1/2 inch, 5th lines accounted.
 Edgewood T. X. 10 1/2
 MADE IN U.S.A.


CURVE I



PYTS DIAGRAMS
 EFFICIENCY VS PRESSURE
 RATIO
 CURVES FOR SIMPLE
 CYCLE GAS TURBINE
 A. BOONARUK RPT. 1947



CURVE III



OUTS DIAGRAMS

EFFICIENCY VS. PRESSURE


RATIO

CURVES FOR SIMPLE CYCLE


50% COMPRESSION

Cooling

A. BODNARUK-RPT-1947



PRESSURE RATIO




NEUFFEL & ESSER CO., N. Y. NO. 385-11
10 X 10 to the 1/2 inch, 50 lines per inch
Electricity, T x 10 in.
MADE IN U.S.A.

EFFICIENCY VS. PRESSURE RATIO
CURVES FOR SINGLE CYCLE
100% COOLING
100% COMPRESSION



PRESSURE RATIO

CURVE IV
PV, TS DIAGRAMS
EFFICIENCY VS PRESSURE RATIO
TURBINE COMPOUNDING
A. BOENKOWSKI, 1947



KEUFFEL & ESSER CO., INC. T. NO. 388-11
 10 x 10 in. 40 mesh 300 lines/cm.
 Copyright © 1947
 MADE IN U.S.A.



CURVE IV



PVTS DIAGRAMS
 EFFVS PRESSURE RATIO
 TURBINE AND COMPRESSOR
 COMPOUNDING 50%
 A. BOBNAK R.P.E. - 1947

PRESSURE RATIO

CURVE VI



PV, TS DIAGRAMS
 EFFICIENCY VS. PRESSURE
 RATIO

CURVES FOR TURBINE

AND COMPRESSOR

COMPOUNDING 100%

A. BOONARUKYAPET 1961

PRESSURE RATIO

10 12

7

6

5

4

3

2

1

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

0

IV. EFFECT OF BLEED-OFF AIR UTILIZATION ON THE VARIOUS SYSTEMS

A. Effects on the Simple Cycle.

The results of the calculation with turbine and compressor efficiency equal to .85, the turbine efficiency of the separate wheel equal to .60, and T_{02} equal to 1500 degrees R are given in Table A. It is to be noted that the temperature of the exhaust gases is comparatively high and it is clear that utilization of this exhaust heat would increase the efficiency of the basic cycle. This is possible by transferring as much heat as possible to the compressed air delivered to the combustion chamber. Thus by reducing the fuel consumption, the overall efficiency of the cycle is improved, as is evidenced by curve I-B at a pressure ratio of 4 to 1. There is no increase in efficiency at pressure ratio 8 or 12 due to the high temperature of the air after compression and the fact that to limit the size of the regenerator we assume a mean temperature differential of 120 degrees. Examining the effect of the utilization of bleed-off air in this simple cycle, we find that the predominant increase occurs in the vicinity of the pressure ratio of 4 to 1; shown by comparison of curve IA to IC, and by comparison of curve IB to ID. As the pressure ratio is further increased

the efficiency effect (i.e., net output B.T.U. per lb. of air) drops off considerably. At the higher pressure ratios, (i.e. 8 and 12 to 1) the compression work increases rapidly, accounting for the sharp decrease in efficiency. This is an important factor to remember in considering the effect of bleed-off utilization upon the systems in general. The increase in efficiency to the basic systems is a dependent function, and depends upon the efficiency tendencies of the basic system. When this basic efficiency is such as to give large quantities of air at end of compression temperature for bleed-off utilization; the corresponding increase in efficiency will be high, as shown by curve ID as compared to curve IA. As pressure ratio is increased the efficiency of the basic cycle drops off (curve IA); thus less air is available for bleed-off utilization and the corresponding increase in efficiency drops off. It is to be noted that as the pressure ratio of compression is increased the temperature of the air leaving the compressor becomes higher and due to this higher temperature we are able to obtain more work from a given amount of bleed-off air, but the difficulty encountered lies in the fact that as the pressure ratio is increased in the basic cycle the overall cycle efficiency drops and less and less air is available for bleed-off. Therefore we can see that the amount of air available for bleed-off utilization is the more important consideration. This factor is in evidence in the examination of curves IA and IC.

B. Effects on Compressor Compounding.

Referring to the curves II and III and checking Table A we find that compounding the compressor yields results showing a substantial increase in the efficiency of the respective cycle. This substantial increase in efficiency being greater the more efficient the intercooling (i.e.- curves IIA₁ compared to IIIA₂; curves IIB₁ to IIIB₂) In analysis the increase is obtained from the reduction of compression work, since the turbine work is essentially the same. In analyzing curve IIA₁, 50% intercooling, it is to be remembered that in intercooling the temperature of the air entering the combustion chamber (T_{01}) is reduced; thus an increase must be made in the quantity of fuel supplied to raise the temperature of the compressed air to 1500 degrees R. Therefore for pressure ratios up to 8 to 1 the efficiency of this cycle remains constant, the reduction in compression work being balanced by the increase in fuel quantity. This reduction of compression work overcomes the increase in fuel in the system of 100% intercooling and thus the efficiency increases to the pressure ratio of 8 to 1. Again the increase in efficiency (curves IIB₁ and IIIB₂) due to regenerator effect is more effective at the lower pressure ratios where the net output in B.T.U. per lb. of air is greatest. In the case of 50% intercooling the effect of utilization of bleed-off air is greater at lower pressure ratios (curve ID₁) and

and drops off rapidly when the pressure ratio is increased above 4 to 1. The net output in B.T.U. per lb. of air in this region of increased pressure ratio drops accordingly. The stabilization effect to the system due to the regenerator is noted in curve IIIB₂. The increase in efficiency in the cycle with 100% intercooling shows marked gains at the pressure ratio of 8 to 1, dropping off rather sharply after this peak is reached (curve IIIC₂). This general trend is followed in the system with 100% intercooling and regeneration (curve IIID₂) but is more or less modified in effect due to the complexity of the system; for the cycle is not then dependent on one function for increase in efficiency. It is seen therefore that the effects of compounding regeneration, and utilization of bleed-off air are a great benefit to the system, for a considerable increase of out-put is gained.

C. Effects on Turbine Compounding.

In this section the expansion in the turbine has been accomplished in two stages. The exhaust gases from the first stage are passed to a second combustion chamber where fuel is again introduced and burned at constant pressure, thus restoring the original maximum temperature to the air. Upon investigation this results in an increase of overall efficiency (curve IVA₃). The added increase in efficiency due

to regenerator effect is quite uniform (curve IV-B₃) and follows the same general trend of curve IV-A₃. These curves show a marked improvement in efficiency; the values at pressure ratio of 4, the efficiency is increased from .089 to .111, an improvement of 30.7 per cent. It is to be noted that when curve IA is compared to curve IV-A₃ at a pressure ratio of 8 the increase in efficiency due to turbine compounding is from .078 to .106, an increase of 35.8 percent. In this system the added increase due to utilization of bleed-off air (curve IV-C₃) follows the same general efficiency trend of the simple turbine compounding system (curve IV-A₃). The accumulative effect of adding the increase in regenerator effect (curve IV-D₃) brings the efficiency to a high level, following the general trend of curves IV-B₃ and IV-C₃. It is interesting to note that the peak efficiency of this system with its various modifications occurs in the vicinity of pressure ratio of 8 to 1. The dotted curve above curve IV-D₃ is the curve IV-D₃ modified by recalculation, found necessary due to inaccuracy of average C_p in this region.

D. Effects on Turbine Compounding and Compressor Compounding.

In consideration of the benefits obtained from separate compounding of the compression (series curves II and III) and turbine compounding (curve IV), it is proposed in this section of the paper to consider a cycle in which the compressor air is compounded and the turbine gases are compounded and the

turbine gases are compounded. To make reasonable comparisons in this study of flexibility the same assumptions were made with respect to turbine efficiency, compressor efficiency, temperature of gases, etc. In this study curve V represents 50% compressor intercooling and turbine compounding and Curve VI represent 100% compressor intercooling and turbine compounding. Since this cycle proposal is by far the most interesting the individual flexibility effects will be considered.

1. In the consideration of the effect of intercooling, curve V-A₄ represents 50% compressor intercooling and turbine compounding and curve VI-A₅ represents 100% compressor intercooling and turbine compounding. It is noted that as the pressure ratio of the systems is increased in the vicinity of 8 to 1 there is a marked improvement in efficiency. It is also noted that this increase in the higher pressure ratios is not very sensitive to the efficiency of intercooling. The relative increase in output is noteworthy. We may conclude that with combined compounding we can expect a profound improvement in efficiency. Output increase is considerable even when we consider the intercooling of 50%.

2. As has been discussed in Section IV A the regenerator effect is important in the consideration of any gas turbine unit. Curve V-B₄ represents the regenerator effect upon turbine compounding and curve VI-B₅ represents the effect upon the system of compressor compounding 100% intercooling. As

suggested in section IV-A we are assuming a mean temperature differential of 150 degrees to limit the size of the regenerator. In analysis the overall efficiencies of the cycles are improved but the effect on output is not very great. This method of heat utilization merely reduces the fuel consumption by the transfer of heat from the exhaust gases to the air prior to entering the combustion chamber.

3. In the study of the effect of bleed-off utilization, curve V-C₄ represents the bleed-off effect upon the 50% intercooling compressor and turbine compounding, curve V-B₄ represents the same system as curve V-C₄ with the effect of a regenerator added; compressor and turbine compounding, curve VI-D₅ represents the same system as curve VI-C₅ with regenerator effect added. In analysis as the pressure ratio is increased in the systems the efficiency of the base cycle goes up, thus making larger quantities of air at higher temperatures available for bleed-off utilization. As the pressure ratio of 8 to 1 is reached the optimum efficiency and output conditions are reached and the effect then levels out, very much in keeping with the tendencies of the base cycle. We may thus conclude that with combined compounding in the vicinity of pressure ratios of 8 to 1 we may expect a marked increase in efficiency and output.

E. Practical Aspects of Results and Recommendations.


In review of the results obtained from the theoretical analysis of stability conditions of the gas turbine unit, the mathematical data, and the interpretation of these results; it appears that bleed-off utilization would serve a very practical purpose. The flexibility of the unit would merely be a matter of preparing a schedule of bleed-off and readjusting existing schedules to conform with the new requirements. The problem does not resolve itself so simply, for although good results were obtained from bleed-off utilization with regard to efficiency and output increase; these gains were predominant in units of varying degree of complexity with additions of compressor intercoolers and turbine compounding combustion chambers. One of the greatest advantages of the gas turbine in its present day development has been the factor simplicity, the unit so assembled with all the apparatus on one shaft and no water required in any of its various stages. The factor of complexity could easily be condoned if the unit would justify the additional expense via added increase in output and efficiency. This is not in the realm of practicality in bleed-off utilization for it is noted that in the units showing good gains in efficiency and output the pressure ratio is in the vicinity of 8 to 1. The assumption made relative to compressor efficiency equal to .85 would not

would not hold at such high pressure ratios. Thus the results obtained as shown in curves V and VI would not hold in view of present day compressor development. The gains in efficiency and output would thus have to be modified and calculations with this factor in mind show a drastic drop in efficiency and output. After careful consideration it is the opinion of the author that in view of present day units and development the proposal of bleed-off utilization, and thus flexibility, would not warrant the expense of the additional turbine wheel.

In keeping with the important thought of gas turbine flexibility the author wishes to propose other avenues in search of this goal. Wet compression in the high pressure ratios merits the investigation of further analysis. Centrifugal turbines have aroused some interest and a complete analysis would be an important contribution. Composite compressors, combining axial flow stages with centrifugal stages, present interesting possibilities for gas turbine units of greater flexibility.

V. SAMPLE CALCULATIONS

It is the purpose of this section to illustrate the method and principles used in the calculation of mathematical material in this paper. At this point it would be appropriate to discuss the accuracy of the results obtained. For ease of computation the specific heat of the exhaust gases is assumed to be that of air; although this method of computation does not give absolute accuracy; the errors involved due to this assumption are so small as to be negligible.



Given data: $T_0 = 530^\circ\text{R}$ $n_c = .85$ $\frac{P_{01}}{P_0} = 4$
 $T_{02} = 1500^\circ\text{R}$ $n_t = .85$

k (for compression) = 1.395 , k (for expansion) = 1.35
 cp (" ") = .241 , cp (" ") = .2644

The general energy equation

$$(1) \quad dL + dQ = C_v dT + \frac{1}{J} P dv + \frac{1}{J} v dP + \frac{1}{Jg} v dv$$

In analysis if we use total temperatures the velocity term in the general energy equation will fall out. Since we can assume in this basic development that the compression is adiabatic ($dQ=0$)

$$(2) dL = C_v dT \int \frac{1}{J} PdV \int \frac{1}{J} VdP$$

Now knowing $Pv = RT$

$$(3) PdV \int VdP = RdT \text{ and substituting in (2)}$$

$$(4) dL = C_v dT \int RdT = (C_v/R) dT = C_p dT$$

VA Simple Cycle

A. Thus the work done by the compressor in compressing the air is

$$(5) dL = W_1 \int_{T_o}^{T_{o1}} C_p dT$$

$$(6) L = W_1 C_p (T_{o1} - T_o) \text{ ideal}$$

$$(7) L_c = \frac{W_1 C_p (T_{o1} - T_o)}{\eta_c} \text{ actual}$$

$$(8) \frac{T_{o1}}{T_o} = \frac{P_{o1}}{P_o}^{\frac{k-1}{k}} ; T_{o1} = T_o \frac{P_{o1}}{P_o}^{\frac{k-1}{k}}$$

$$T_{o1} = 530 (4)^{.283} = 787^\circ \text{ R ideally}$$

$$(9) L_c = \frac{.241 (257)}{.85} = 73 \text{ BTU/lb. air compressed}$$

B. Turbine Calculations

k for air at $1500^\circ \text{R} = 1.350$, $C_p = .2644$

$$(1) T_{o2} = \frac{P_{o2}}{P_{o3}}^{\frac{k-1}{k}} ; \frac{1500}{T_{o3}} = (4)^{.259} ; T_{o3} = \frac{1500}{1.432} = 1045^\circ \text{R}$$

$$(2) L_t = C_p \eta_t (T_{o2} - T_{o3}) = (.2644) (.85) (455)$$

$$L_t = 102.6 \text{ BTU/lb air compressed}$$

Now net work available for power and bleed off is

$$(3) 102.6 - 73 = 29.6 \text{ BTU/lb. air}$$

and since we are assuming that we will be at half load there

will be 14.8 BTU/lb. air available for power purposes and 14.8 BTU/lb air available for bleedoff to atmosphere.

C. In order to calculate the efficiency of the cycle we must find the weight of fuel necessary to sustain the cycle under conditions of half load. Fuel used will be kerosene, with a L.H.V. equal to 1900 BTU/lb.

The weight of air for net power purposes will be (from work term balance)

$$(1) 73 W_1 + 29.6 W_x = 102.6 (W_1 - W_x)$$

$$W_x = .224 \text{ lb air/sec}$$

Writing a heat balance for combustion we obtain

$$(2) W_1 - W_x \int_{T_{01}}^{T_{02}} C_p dT = w H = 1900w$$

$$(3) C_p \text{ average} = \frac{.241 + .264}{2} = .257$$

$$(4) w = \frac{.776 (.257)(668)}{19000} = .00727 \text{ lb fuel/lb air/sec}$$

$$\eta_{\text{cycle}} = \frac{C_{p1} (1/w) n_t (T_{02} - T_{03}) - \frac{C_{p2}}{n_c} (T_{01} - T_0)}{C_{p3} (1/w) (T_{02} - T_{01}) \text{ actual}}$$

$$\eta_{\text{cycle}} = \frac{14.8 \text{ BTU/lb air/sec}}{168.5 \text{ BTU/lb air sec}} = .0885 \text{ at half load}$$

D. From the 14.8 BTU/lb air bleed off we will try to reclaim some work via turbine wheel as proposed. We will assume efficiency equals .60 for this separate turbine wheel. We know that the temperature of this bleed-off air is the discharge temperature of the compressor.

$$T_{01} = 832^\circ \text{ R actual, } T_0 = 530^\circ \text{ R}$$

$$\frac{P_{01}}{P_0} = 4, C_p = .241, W_{x2} = .112 \text{ lb. air/sec.}$$

Thus with this given data the additional amount of work obtainable is

$$(1) L = W_{x2} C_p n_w (T_{01} - T_0) = (.112)(.6)(.241)(302) = 5.75 \text{ BTU lb air}$$

The cycle efficiency with utilization of bleed-off air as proposed will now be

$$(2) \eta_{\text{cycle}} = \frac{(14.8 - 5.75) \text{ BTU/lb air}}{168.5 \text{ BTU/lb air}} = \text{at half load}$$

E. Percentage increase of efficiency

$$(1) \frac{.0245}{.0885} = .277$$

F. Percentage increase of output

$$(1) \frac{5.75}{14.8} = .389$$

V B Compounding the Compression - 50% Intercooling

A. We shall accomplish the compression in two stages such that $\frac{P_{0a}}{P_0} = \frac{P_{01}}{P_{0a}}$ or $P_{0a} = (P_0 P_{01})^{\frac{1}{2}}$, which yields minimum work. The intercooling reduces the temperature of the air at P_{0a} . When the temperature of the air is reduced to the temperature of the air at P_0 it has been subjected to what may be called perfect cooling.

$$(1) P_{0a} = 2; T_{0a} = T_0 \frac{P_{0a}}{P_0}^{\frac{k-1}{k}} = 530 (1.216) = 640^\circ \text{R}$$

$$(2) L_{c1} = \frac{W_1 C_p (T_{0a} - T_0)}{n_c} = \frac{.241 (110)}{.85} = 31.3 \text{ BTU/lb air}$$

With 50 per cent intercooling $T_0 = 595^\circ \text{R}$

$$(3) T_{01} = 595 (1.232) = 732^{\circ} R$$

$$(4) L_{c2} = \frac{.241 (137)}{.85} = 38.8 \text{ BTU /lb air}$$

$$(5) L_{c1} \neq L_{c2} = 70.1 \text{ BTU/lb air}$$

B. Turbine Calculations

$$(1) (1) \text{ from VA-B } L_t = 102.6 \text{ BTU/lb air}$$

Net Work

$$(2) 102.6 - 70.1 = 32.5 \text{ /lb air}$$

$$C. T_{01} \text{ actual} = 756^{\circ} R$$

$$(1) 69.2 W_1 \neq 35.5 W_x = 102.6 (W_1 - W_x)$$

$$W_x = .257 \text{ lb air/sec/lb compressed air}$$

Solving for fuel air ratio as is VA-C-(2),(3)

$$(4) w = \frac{.743(.257)(756)}{19000} = .00765 \text{ lb fuel/lb air/sec}$$

$$(5) n_{\text{cycle}} = \frac{16.25 \text{ BTU/lb air/sec}}{186.5 \text{ BTU/lb air/sec}} = .0870 \text{ at half load}$$

D. Solving for increase in turbine work by use of bleedoff air

$$(1) L = .178 (.241)(218.5) = 6.61 \text{ BTU/lb air}$$

$$(2) n_{\text{cycle}} = \frac{(16.2 \neq 6.61)}{186.5} = .101$$

E. Percentage increase of efficiency

$$(1) \frac{.014}{.0870} = .161$$

F. Percentage increase of output

$$(1) \frac{6.61}{16.2} = .409$$

G. Solving for increase in turbine work due to bleed-off air plus regenerator effect.

$$(1) L = 6.61 \neq 3.62 = 10.23 \text{ BTU/lb air}$$

$$(2) \ n_{\text{cycle}} = \frac{26.43}{186.5} = .142$$

H. Percentage increase of efficiency

$$(1) \ \frac{.054}{.087} = .62$$

I. Percentage increase of output

$$(1) \ \frac{10.23}{16.2} = .63$$

V C Compounding the Compression - 100% Intercooling

A. Compressor

$$(1) \ L_{c1} = 33 \text{ BTU/lb air for 1st stage}$$

$$(2) \ L_{c2} = 33 \text{ BTU/lb air for 2nd stage}$$

$$(3) \ L_{c1} + L_{c2} = 66 \text{ BTU/lb air}$$

B. Turbine Calculation

$$(1) \ \text{from VA-B } L_t = 102.6 \text{ BTU lb air}$$

Net Work

$$(2) \ 102.6 - 66 = 36.6 \text{ BTU/lb air}$$

C. $T_{c1} \text{ actual} = 666.5^\circ \text{ R}$

$$(1) \ 66 w_1 + 36.6 w_x = 102.6 (w_1 - w_x)$$

$$w_x = .262 \text{ lb air/sec/lb air}$$

Solving for fuel air ratio as VA-C (2), (3)

$$(4) \ w = \frac{.738 (257) (833.5)}{19000} = .0083 \text{ lb fuel/lb air/sec}$$

$$(5) \ n_{\text{cycle}} = \frac{18.3 \text{ BTU/lb air/sec}}{208 \text{ BTU/lb air/sec}} = .088$$

D. Solving for increase in turbine work by using bleed-off air as proposed

$$(1) \ L = \frac{.131 (.241) (136.5)}{1} = 3.04 \text{ BTU/lb air}$$

$$(2) \ n_{\text{cycle}} = \frac{(18.3 + 3.04)}{208} = .102$$

E. Percentage increase of efficiency

$$(1) \frac{.014}{.058} = .159$$

F. Percentage increase in output

$$(1) \frac{3.04}{18.3} = .166$$

V D Comounding the Turbine

A. The large surplus of air needed to keep the maximum temperature of the hot gases to a reasonable level is in analysis a detriment to high efficiency. The fuel supply is limited to an amount needed to raise the temperature of the air from T_{d1} to T_{d2} . We now arrange the expansion in the turbine in two stages. By passing the exhaust gases from the first stage to a heating chamber the original maximum temperature is restored to the gases. In this manner we can investigate the possibilities of a more efficient way in which to use the air.

$$(1) P_{ob} = \frac{P_{o2}}{2} ; \text{ this ratio assumed because it yields}$$

higher efficiency than the geometric mean between P_2 and P_3

$$(2) \frac{T_{o2}}{T_{ob}} = \left(\frac{P_{o2}}{P_{ob}} \right)^{\frac{k-1}{k}} ; \frac{1500}{T_{ob}} = (2)^{.259} ; T_{ob} = \frac{1500}{1.197} = 1250^{\circ} R$$

$$T_{ob \text{ actual}} = 1294^{\circ} R$$

$$(3) L_{t1} = C_p n_t (T_{o2} - T_{ob}) = .2644 \times .85 \times 250 = 56.3 \text{ BTU/lb air}$$

$$(4) L_{t2} = C_p n_t (T_{o2} - T_{ob}) = 56.3 \text{ BTU/lb air}$$

$$(5) L_{t1} + L_{t2} = 112.6 \text{ BTU/lb air}$$

Now net work available for power and bleed-off is

$$(6) \quad 112.6 - 73 = 39.6 \text{ BTU/lb air}$$

therefore 17.8 BTU/lb air is available for bleed-off to atmosphere.

B. Weight of air for net power purposes will be:

$$(1) \quad 73 W_1 - 39.6 W_x = 112.6 (W_1 - W_x)$$

$$W_x = .262 \text{ lb air/sec}$$

C. Weight of fuel used

$$(1) \quad w = \frac{.738 (.262) (910)}{19000} = .00905 \text{ lb fuel/.738 lb air/sec}$$

$$(2) \quad n_{\text{cycle}} = \frac{17.8}{222} = .089 \text{ at half load}$$

D. Efficiency calculation with regenerator

$$(1) \quad n_{\text{cycle}} = \frac{24.6}{222} = .111 \text{ at half load}$$

V E Regenerator with Compressor and Turbine Compounding

A. In this section of the paper we will give consideration to the utilization of the heat valve in the exhaust gases in heating the discharge air from the compressor before it enters the burner chamber. In thus heating the compressed air to a temperature near that of the exhaust we have to supply a decreased amount of fuel to bring it to the final maximum temperature. To limit the size of the heat inter-changer we will limit the temperature exhaust gases to 120 degrees. To illustrate the problem method let us compute the added efficiency due to regenerator effect for combined compressor and turbine compounding. (VD- B3)

$$(1) T_{01} = 666.5^{\circ} R$$

$$(2) T_{03} = 1294^{\circ} R$$

$$(3) T_{0b} = 1144^{\circ} R; \text{ temperature of air after regenerator effect.}$$

\ The amount of fuel necessary to raise .708 lb air from $1144^{\circ} R$ to $1500^{\circ} R$ equals

$$(4) w = \frac{.708 (.257) (.356)}{19000} = .0032 \text{ lb fuel} / .708 \text{ lb air}$$

which adds heat equivalent of 6.2 BTU/lb air to the cycle

$$(5) .0032 (19,000) = 6.2 \text{ BTU/lb air}$$

Thus

$$(6) \eta_{\text{cycle}} = \frac{(23.3 + 6.2)}{253} = .115$$

or percentage increase in efficiency of 26 per cent. Additional turbine wheel effect for bleed off air

$$(7) \quad n_{\text{cycle}} = \frac{34.05}{25.3} = .134$$

or percentage increase over (a) in efficiency of 52.2 per cent

B. Net work available for power and bleed-off in the various cycles.

$$(1) \text{ Simple cycle: } 112.6 - 73 = 39.6 \text{ BTU/lb air}$$

$$(2) \text{ Compressor intercooling, 50 percent: } 112.6 - 70.1 = 42.5 \text{ BTU/lb air}$$

$$(3) \text{ Compressor intercooling 100 percent: } 112.6 - 66 = 46.6 \text{ BTU/lb air}$$

C. Fuel weight and efficiency calculations

(1) Simple cycle

$$(a) \quad 73 \quad W_1 \nearrow 39.6 \quad W_x = 112.6 (W_1 - W_x)$$

$$W_x = .260 \text{ lb air/sec}$$

$$(b) \quad w = \frac{(.74)(.257)(668)}{19000} = .0068 \text{ lb fuel/lb air/sec}$$

$$(c) \quad n_{\text{cycle}} = \frac{19.2}{216} = .089 \text{ at half load}$$

$$(d) \quad L(\text{increased}) = (.13)(.241)(302) = 6.65 \text{ BTU/lb air}$$

$$(e) \quad n_{\text{cycle}} = \frac{25.85}{216} = .120$$

$$\text{Percentage increase of efficiency} = .33$$

$$\text{Percentage increase of output} = .346$$

(2) Cycle with compressor intercooling, 50%

$$(a) \quad 70.1 \quad W_1 \nearrow 42.5 \quad W_x = 112.6 (W_1 - W_x)$$

$$W_x = .279 \text{ lb air/sec}$$

$$(b) \quad w = \frac{(.721)(.257)(756)}{19000} = .00738 \text{ lb fuel/lb air/sec}$$

$$(c) \quad n_{\text{cycle}} = \frac{21.25}{243} = .0875 \text{ at half load}$$

$$(d) L(\text{increase}) = (.139)(.241)(218.5) = 5.2 \text{ BTU/ lb air}$$

$$(e) n_{\text{cycle}} = 21.25 \div 5.2 = .109$$

$$(f) \text{ Percentage increase of efficiency} = .24$$

$$(g) \text{ Percentage increase of output} = .234$$

(3) Cycle with compressor intercooling, 100%

$$(a) 66 W_1 \div 46.6 W_x = 112.6 (W_1 - W_x)$$

$$W_x = .292 \text{ lb air/sec}$$

$$(b) n_{\text{cycle}} = \frac{23.3}{25.3} = .0885$$

$$(c) w = \frac{(.708)(.257)(833.5)}{19000} = .0080 \text{ lb fuel/lb air/ sec}$$

$$(d) L(\text{increase}) = (.96)(.241)(136.5) = 4.55 \text{ BTU/lb air}$$

$$(e) n_{\text{cycle}} = \frac{23.3 \div 4.55}{253} = .11$$

$$(f) \text{ Percentage increase of efficiency} = .13$$

$$(g) \text{ Percentage increase of output} = .195$$

BIBLIOGRAPHY

1. Bailey, Neil P., "Gas Turbine Combustion and Stability" Section G1, Compressor Stability; G2, Compressor-Burner Stability. Lecture Notes, Rensselaer Polytechnic Institute.
2. Meyer, "The Combustion Gas Turbine", Mech. Eng., 1939
3. Rettaliata, "The Combustion Gas Turbine", Trans. A.S.M.E., 1941
4. Davies, S.J., and Fawzi, M. I. "Outputs of Combustion Turbines", Engineering, March 1944.
5. Stodola, "Steam and Gas Turbines", McGraw-Hill

Thesis

6083

B6

Bodnaruk

An investigation of
the efficiency effects
of gas turbine flex-
ibility with bleed-off
utilization.

Thesis

6083

B6

Bodnaruk

An investigation of
the efficiency effects
of gas turbine flex-
ibility with bleed-off
utilization.



OPRESS BINDER

BGS 2507


MADE BY

O PRODUCTS, INC.

ISLAND CITY, N. Y., U. S. A.

thesB6

An investigation of the efficiency effec



3 2768 002 07448 6

DUDLEY KNOX LIBRARY